



# 中国国家强制性产品认证证书

证书编号：2024010305650823

**认证委托人名称及地址**

IDEC 株式会社  
日本大阪市淀川区西宫原2丁目6番64号

**生产者名称及地址**

IDEC 株式会社  
日本大阪市淀川区西宫原2丁目6番64号

**生产企业名称及地址**

IDEC 株式会社-福崎工厂  
日本兵库县神崎郡福崎町西治字拜尾 860-2

**产品名称和系列、型号、规格**

安全模块

HR5S; Ui:250V; Uimp:4kV; AC-15:Ue/Ie: AC240V/2A; DC-13:Ue/Ie: DC24V/1A;  
Ith:3A;防护等级:IP20. 型号解释详见附页

**产品标准和技术要求**

GB/T 14048.5-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》  
(CNCA-C03-02:2024) 的要求，特发此证。

发证日期：2024年07月02日 有效期至：2029年07月01日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，  
也可在认监委网站（www.cnca.gov.cn）查询。



签发：

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

**CERTIFICATE NO.:** 2024010305650823

## NAME AND ADDRESS OF THE APPLICANT

IDEC CORPORATION

6-64 Nishimiyahara 2-chome, Yodogawa-Ku, Osaka 532-0004 Japan

## NAME AND ADDRESS OF THE MANUFACTURER

IDEC CORPORATION

6-64 Nishimiyahara 2-chome, Yodogawa-Ku, Osaka 532-0004 Japan

## NAME AND LOCATION OF THE FACTORY

IDEC CORPORATION - FUKUSAKI PLANT

860-2 Saiji Aza-Haio Fukusaki-Cho, Kanzaki-Gun, Hyogo-Ken 679-2215 Japan

## PRODUCT NAME,MODEL AND SPECIFICATION

Safety Module

HR5S; Ui:250V; Uimp:4kV; AC-15:Ue/Ie: AC240V/2A; DC-13:Ue/Ie: DC24V/1A; Ith:3A;Levels of Protection:IP20. See attached page for details

## STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

**Valid from:** Jul.02,2024

**Valid until:** Jul.01,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





# 中国国家强制性产品认证证书

证书编号：2024010305650823

证书附页：第 1 页 共 1 页

型号的解释：

HR5S - C2 D T025  
(1) (2) (3)

HR5S 安全模块

- (1) 监测类型和输出回路数量  
C2：用于急停开关和限位开关的监控.2NO.
- (2) 产品类型
  - S-Simple type
  - B-Basic type
  - D-OFF-delay type
- (3) 关闭延迟时间
  - Blank-no OFF-delay
  - T025-0.25 Sec.
  - T050-0.5 Sec.
  - T100-1 Sec.
  - T200-2 Sec.
  - T400-4 Sec.

本页为证书附页，应与证书主页同时使用。



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司